

Office of the Fire Commissioner



Codes and Standards - Fire Safety Inspections

Standardized Labels Required for Fire Protection Equipment/Life Safety Installation Inspection, Testing and Cleaning

Date Issued: January 8, 2016

The Office of the Fire Commissioner (OFC) in partnership with industry stakeholders and municipalities, has developed standardized labels for placement on fire protection equipment, life safety installations and other equipment mandated for inspection, testing and cleaning under the Manitoba Fire Code.

The first label is intended to be affixed, by the servicing company, to the equipment that has been cleaned, inspected, or tested, and serves as a quick reference that identifies:

1. The date of inspection, address and technician's name.
2. The servicing company's name and logo.
3. If the system is functional or deficient.
4. The next inspection, testing, or cleaning date.

The second label is to be applied after the deficiencies have been corrected.

The OFC supports the implementation of the attached labels by industry. The labels will provide consistency for both design and information requirements across the province. Label standardization will enhance both the public's and local inspectors' ability to determine the readiness of life-safety systems.

The OFC recommends local authorities adopt the attached label design through municipal by-law.

Please refer to attached design recommendation.

508—401 York Avenue
Winnipeg Manitoba R3C 0P8
T: 204 945-3322
F: 204 948-2089
Toll Free: 1-800-282-8069 (in Manitoba only)
24 Hour Emergency Line: 1-888-389-3473
Website: www.firecomm.gov.mb.ca



Office of the Fire Commissioner



Codes and Standards - Fire Safety Inspections

Standardized Labels Required for Fire Protection Equipment/ Life Safety Installation Inspection, Testing and Cleaning

Date Issued: January 8, 2016

SAMPLE LABEL 1

This label verifies that this Fire Protection/Life Safety Installation has been inspected, tested and cleaned in accordance with the Manitoba Fire Code as of:

JAN 2014	FEB 2015	MAR 2016	APR 2017	MAY 2018	JUN 2019	JUL 2020	AUG 2021	SEP 2022	OCT 2023	NOV 2024	DEC 2025
-------------	-------------	-------------	-------------	-------------	-------------	-------------	-------------	-------------	-------------	-------------	-------------

Fire Protection/Life Safety/Installation address: _____

Technician Name _____
Please Print Signature

COMPANY NAME & LOGO

This label is NOT a substitute for a report where required by the Manitoba Fire Code. Reference the report if applicable for detailed results of the inspection, test, and/or cleaning of this Fire Protection/Life Safety Installation.

The Fire Protection/Life Safety Installation is fully functional	Yes <input type="checkbox"/>	No <input type="checkbox"/>
The Fire Protection/Life Safety Installation <u>has</u> deficiencies	<input type="checkbox"/>	<input type="checkbox"/>

The next inspection, test or cleaning is required as of: _____
D-D M-M Y-Y-Y-Y

SAMPLE LABEL 2

Deficiencies found during this inspection, test and cleaning have since been corrected by:

Technician Name _____ Signature _____
Please Print

Date _____
D-D M-M Y-Y-Y-Y

Note: These are two separate labels. The second label (with RED font) is to be applied after the deficiencies have been corrected.

508—401 York Avenue
Winnipeg Manitoba R3C 0P8
T: 204 945-3322
F: 204 948-2089
Toll Free: 1-800-282-8069 (in Manitoba only)
24 Hour Emergency Line: 1-888-389-3473
Website: www.firecomm.gov.mb.ca

